

**ANNEXURE-III**

**GENERAL DESIGN PARAMETERS FOR INLET EFFLUENT QUALITY**

Sl.No	Parameter	Range
1	pH	2-12
2	Acidity	20,000 mg/l
3	Alkalinity	20,000 mg/l
4	Hexavalent Chromium	2500 mg/l
5	Cyanide	2000 mg/l
6	Total Dissolved Solids	50,000 mg/l
7	Fluoride	2000 mg/l
8	Zinc	200 mg/l
9	Lead	20 mg/l
10	Copper	40 mg/l
11	Nickel	150 mg/l
12	Cadmium	10 mg/l

*J. Damer*  
**SENIOR ENVIRONMENTAL OFFICER**  
**Waste Management Cell**

*27/10/12*